

SECTION 23 00 15

ELECTRICAL COORDINATION FOR MECHANICAL EQUIPMENT

This document is intended to note the Owners Design Requirements (ODR) for the titled specification section. Design professional to review and integrate ODR into the project's technical specifications. This ODR document should not be viewed as a standalone technical specification.

PART 1 - GENERAL REQUIREMENTS

N/A

PART 2 - PRODUCTS AND MATERIALS

N/A

PART 3 - EXECUTION

◆ CONTRACTOR COORDINATION

- Unless otherwise indicated, all motors, equipment, controls, etc. shall be furnished, set in place and wired in accordance with Table below. Any items not listed but shown on the drawings shall be considered part of the Contract Documents and brought to the attention of the Owner.
- The General Contractor is the central authority governing the total responsibility of all trade contractors. Therefore, deviations and clarifications of this schedule are permitted provided the General Contractor assumes responsibility to coordinate the trade contractors different than as indicated herein. If deviations or clarifications to this schedule are implemented, submit a bid question to the Owner.

RESPONSIBILITY MATRIX					
ITEM	FURNISHED BY	SET BY	POWER WIRING	CONTROL WIRING	RACEWAY
Thermostats (low voltage)	Div 23c	Div 26	-	Div 26	Div 26
Thermostats (line voltage)	Div 23c	Div 26	Div 26	-	Div 26
control valves	Div 23c	Div 23m	-	Div 26	Div 26
control dampers	Div 23c	Div 23m	-	Div 26	Div 26
motors	Div 23m	Div 23m	Div 26	Div 26	Div 26
VFDs	Div 23m	Div 23m	Div 26	Div 26	Div 26
Relays and Transformers	Div 23c	Div 23c	Div 26	Div 26	Div 26
<i>Legend</i>					
<i>Div 23m - Mechanical Contractor</i>					
<i>Div 23c - Controls Contractor (Honeywell)</i>					
<i>Div 26 - Electrical Contractor</i>					