

SECTION 09 90 00

PAINTS AND COATINGS

This document is intended to note the Owners Design Requirements (ODR) for the titled specification section. Design professional to review and integrate ODR into the project's technical specifications. This ODR document should not be viewed as a standalone technical specification.

PART 1 - GENERAL REQUIREMENTS

◆ EXTRA STOCK

- Provide five gallons (one container) of each color and surface texture to Owner.
- Label each container with color, texture, and Terminal/room locations, in addition to the manufacturer's label.
- Provide chart showing manufacturer, color and mixing formula of all colors of paint and stain installed.

PART 2 - PRODUCTS AND MATERIALS

◆ Manufacturers:

- Vista Paint
- Dunn-Edwards
- Spectra-Tone
- Frazee
- Sherwin Williams

◆ PAINT SYSTEMS (DFT = Dry Film Thickness)

- Masonry/Concrete, Opaque, Acrylic:
 - Flat: Elastomeric Coating System, 15-18 mils DFT Smooth texture.
- Ferrous Metals, Unprimed, Alkyd / Latex, 3 Coat:
 - One coat of alkyd primer or 100% acrylic rust inhibitive metal primer, 1.25 mils DFT.
 - Semi-gloss: Two coats of vinyl-acrylic latex enamel, 3.5 mils DFT
- Ferrous Metals, Primed, Latex, 2 Coat:
 - Touch-up with alkyd primer or 100% acrylic rust inhibitive metal primer, 1.25 mils DFT.
 - Semi-gloss: Two coats of vinyl-acrylic latex enamel, 3.5 mils DFT.
- Galvanized Metals, Latex, 3 Coat:
 - One coat galvanize primer, 1.3 mils DFT
 - Semi-gloss: Two coats of vinyl-acrylic latex enamel, 3.5 mils DFT
- Aluminum, Unprimed, Alkyd, 3 Coat:
 - One coat etching primer.
 - Semi-gloss: Two coats of alkyd enamel, 2.0 mils DFT.
- Gypsum Board/Plaster, Latex-Acrylic, 3 Coat:
 - One coat of drywall finish prep coat.
 - One coat of prep coat flat latex primer, 1.2 mils DFT.
 - Gloss: Two coats of vinyl-acrylic latex enamel; ceiling and soffit surfaces, 2.8 mils DFT.
 - Semi-gloss: Two coats of acrylic enamel; wall/ceiling surfaces, 2.8 mils DFT.
- Cement Plaster, Opaque, Acrylic / Latex, 3 Coat:
 - One coat of 100 percent acrylic primer sealer.
 - Flat: Two coats of 100% acrylic elastomeric, 12.0 mils DFT.

SECTION 09 90 00

PAINTS AND COATINGS

This document is intended to note the Owners Design Requirements (ODR) for the titled specification section. Design professional to review and integrate ODR into the project's technical specifications. This ODR document should not be viewed as a standalone technical specification.

PART 3 - EXECUTION

N/A

END OF SECTION