

SECTION 08 31 13

ACCESS DOORS AND FRAMES

This document is intended to note the Owners Design Requirements (ODR) for the titled specification section. Design professional to review and integrate ODR into the project's technical specifications. This ODR document should not be viewed as a standalone technical specification.

PART 1 - GENERAL REQUIREMENTS

N/A

PART 2 - PRODUCTS AND MATERIALS

♦ ACCESS DOORS AND FRAMES

- Provide flush access doors with exposed flanges.
- Retain "Manufacturers" Subparagraph below and insert list of manufacturers to require products from manufacturers listed or a comparable product from other manufacturers.
 - Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following:
 - a. Milcor.
 - b. Larsens.
 - c. Karp.
 - d. Nystrom.

♦ MATERIALS

- Steel Sheet: Uncoated or electrolytic zinc coated, with cold-rolled steel sheet substrate complying with ASTM A 1008/A 1008M, Commercial Steel (CS), exposed.
- Latch and Lock Hardware: All access doors shall be key lockable by Corbin Russwin lock.
 - Quantity: Furnish number of latches and locks required to hold doors tightly closed.
 - Mortise Cylinder Preparation: Provide Corbin Russwin cylinder lock.

♦ FINISHES

- Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
- Protect mechanical finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.
- Painted Finishes: Comply with coating manufacturer's written instructions for cleaning, conversion coating, and applying and baking finish.
 - Factory Primed: Apply manufacturer's standard, lead- and chromate-free, universal primer immediately after surface preparation and pretreatment.

PART 3 - EXECUTION

N/A

END OF SECTION