

SECTION 26 22 00

LOW-VOLTAGE TRANSFORMERS

This document is intended to note the Owners Design Requirements (ODR) for the titled specification section. Design professional to review and integrate ODR into the project's technical specifications. This ODR document should not be viewed as a standalone technical specification.

PART 1 - GENERAL REQUIREMENTS

N/A

PART 2 - PRODUCTS AND MATERIALS

- ◆ Transformers - general requirements
 - All transformers shall have copper windings.
 - Transformers shall be sized to achieve maximum bus rating of panel boards.

PART 3 - EXECUTION

N/A

END OF SECTION